

AFC OIL/WATER SEPARATOR H20: 50 & 150 GPM TREATMENT RATES

REFERENCE STANDARDS

- 1) G30.12-M1977, 'BILLET STEEL BARS FOR CONCRETE REINFORCEMENT'
- 2) CAN/CSA-A23.1-00, 'CONCRETE MATERIALS AND METHODS OF CONCRETE CONSTRUCTION' WITH SUPPLEMENTS.
- 3) CAN/CSA-A23.1-00, A23.2-00 'METHODS OF TEST FOR CONCRETE'
- 4) CAN/CSA-B66-05, 'PREFABRICATED SEPTIC TANKS AND SEWAGE HOLDING TANK'

GENERAL NOTES:


- 1) CONCRETE COMPRESSIVE STRENGTH = 30MPa AT 28 DAYS.
- 2) COARSE AGGREGATE SIZE = 2.5mm to 20mm.
- 3) TENSILE STRENGTH OF REINFORCEMENT STEEL = 400MPa.
- 4) BREAKING STRENGTH OF LIFTING CABLES = 9800Lbs (4455Kg) EACH. (FOUR PER TANK OR LID)
- 5) FOUR TAILED CHAINS SHOULD BE USED FOR LIFTING THE LID & TANK INTO PLACE TO ENSURE VERTICAL LIFTING FORCE AT LIFTING LOCATIONS, AND PREVENT POSSIBLE DAMAGE TO THE SEPARATOR.
- 6) DEAD WEIGHT OF OIL SEPARATOR = 9900Lbs (4500Kg).
 LID = 3150Lbs (1432Kg)
 TANK = 6750Lbs (3068Kg)

PATENT & COPYRIGHT INFORMATION

- 1) US PATENT No. IS 6,079,571 AND THE CANADIAN PATENT No. IS 2,252,307.
 PLEASE NOTE THAT THE PATENT COVERS BOTH THE OIL/WATER SEPARATOR AND THE AFC COALESCING PACKAGE. AFC INC. WILL VIGOROUSLY DEFEND ITS PATENT RIGHTS IN ANY AND ALL CASES OF INFRINGEMENT.
- 2) ALL SHOP DRAWINGS, SCHEDULES, PAMPHLETS AND INFORMATION SHEETS ARE COPYRIGHTED BY AFC INC. NOTHING IS TO BE REPRODUCED WITHOUT THE EXPRESS WRITTEN CONSENT OF AFC INC.

NOTES:

REVISED: FEB 1 2006

	3891 Irvine Road LAKE COUNTRY, B.C. V4V 2G4	BY: PKR	AFC OIL/WATER SEPARATOR 50 or 150 GPM : H20	ITEM NO.
	PH: (250) 548-0056	DATE: FEB 1 06		1605 NOTES
	FX: (250) 765 0820	SCALE: NTS		